



Bid Addendum

Page 1 of 1

ADDENDUM NO.: 2

DATE OF ADDENDUM: December 31, 2014

**Town of Mansfield, Connecticut
Storrs Center Town Square Structural Elements Bid**

Original Bid Due Date / Time: January 8, 2015 at 2:00 PM

Revised Bid Due Date / Time: January 13, 2015 at 2:00 PM

TO: Prospective Bid Proposers:

This Addendum forms part of the "Contract Documents" and modifies or clarifies the original "Contract Documents" for this Project dated December 2015. Prospective Bid Proposers shall acknowledge receipt of the total number the Addenda issued for this Project on the space provided on the Bid Form/Proposal. Failure to do may subject Bid Proposers to disqualification.

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

Question: Due to the holiday period and our need to retrieve information from various sources and subs, we would like to request an extension to the current bid deadline of January 8th: please let me know if January 13th would be acceptable?

The bid due date has been extended to January 13, 2015 at 2:00 PM. Please note no extension has been provided for the project completion date of March 31, 2015.

Item 2

Question: The ACRYLITE® Satinice tube has the same appearance as sand-blasted tube. Does the specifier know this? Also, if they still insist on having tube sand-blasted, please note that we do not offer a cast tube.

The intention of the design is for the tubes to look the same. The suppliers of each are different and the only tube that is to be purchased from Acrylite is the Satinice tube. The Acrylite Satinice comes in a limited number of sizes so it cannot be used behind the perforations of the steel. The Acrylite Satinice tube is fabricated with microbeads in the acrylic which diffuse light and that is the reason we are using them for the beacon caps. The cast acrylic is readily available from a number of suppliers and it is up to the contractor to choose the supplier and complete the sand blasting.

All questions must be in writing and must be forwarded to the Town of Mansfield Director of Public Works, John C. Carrington at 860-429-3332 or via e-mail at John.Carrington@mansfieldct.org.

End of Addendum No. 2